



Mallett Consulting, Inc.

ENGINEERING - SURVEYING - PROJECT MANAGEMENT

101 DEVANT STREET, SUITE 804
FAYETTEVILLE, GEORGIA 30214
770-719-3333
770-719-3377 (fax)

ADDENDUM NO. 1

Date: June 10, 2019
Project: Downtown Sidewalk and Parking Improvements
For The Town of Brooks, Georgia

Bid Date : June 13, 2019

ITEM DESCRIPTION

1. *Clarification* – There are 4 existing decorative street lights. Each of these four lights will be replaced with a new decorative street light within 20 LF of each existing location. Wire for extension shall be copper wire with SCH 80 PVC conduit, minimum 18" deep. Price shall include 14' light pole with fixture and bulb.
2. Temporary, all weather surfaces shall be provided during sidewalk construction to allow pedestrian access to existing businesses along the project. Cost for this requirements shall be included in the bid item for Traffic Control.
3. Price for Pavestone City Stone XL shall be based on 12x24 pavers (2 colors maximum.)
4. Bid Item No. 8 shall include edge milling as necessary to remove excess asphalt along remaining gutter on east side of road, such that top of new overlay pavement is no more than 1" above top of gutter. (Top of overlay shall match new gutter along West side of road).
5. *Clarification* - Existing crown in road shall remain unchanged after overlay and striping and will be offset from new roadway centerline.

End of Addendum No. 1